

Heilsufrøðiliga starvsstovan
Smyrilsvegur 7, 2. hædd
FO-100 Tórshavn
Att.: kemi@hfs.fo

Report code: AR-21-CA-21106906-01
Batch code: EUDKVE-21106906
Client code: CA0000578
Received on: 23.09.2021

Analytical Report

Sampling Point	Drikkevand fra Færøerne - / 4999110200
Sample type:	Drinking water - Other
Sampling:	21.09.2021 . 10:00
Sampler:	Rekvirenten
Test period:	23.09.2021 - 29.09.2021

Sample description: 21-02747-1


Lab sample No.:	835-2021-10690601	Unit	Limit values		LOQ	Method	Urel (%)
			Min.	Max.			
Inorganic Compounds							
Nitrites (NO ₂)	< 0.001	mg/l			0.001	SM 17. ed. 4500-NO ₂ (B)	15
Nitrate	3.5	mg/l			0.3	SM 17. ed. 4500-NO ₃ (H)	15
Chloride	12	mg/l			1	SM 17. ed. 4500-Cl (E)	15
Fluoride	0.051	mg/l			0.05	SM 17. ed. 4500-F (E)	15
Sulphate	2.4	mg/l			0.5	SM 17. ed. 4500-SO ₄ (E)	15
Cyanide, total	< 1	µg/l			1	DS/EN ISO 14403:2012	15
Information from client							
Accredited sampling	No					*	

Batch comments:

Since the samples are received after 24 hours from time of sampling the results on analyses which should be conducted within the first day should be interpreted with caution.

29.09.2021

Customer center
 Tel 70224256
 Rentvand@eurofins.dk


 Ulla Bøgedal
 Customer Advisor

Legend:

<: less than

>: greater than

#: none of the parameters are detected

LOQ Limit of quantification

*): Not included in the accreditation

n.d: not detected

NM: non-measurable

Urel (%): The expanded relative measurement uncertainty, with a coverage factor 2. For results at the level of detection limit the uncertainty might be higher than reported.

°): Uncertainties of microbiological parameters are given as a logarithmical standard deviation

The test results relate only to the items tested.

The report shall not be reproduced except in full without the written approval of the testing laboratory.