

Heilsufrøðiliga starvsstovan
Smyrilsvægur 7, 2. hædd
FO-100 Tórshavn
Att.: kemi@hfs.fo

Report code: AR-23-CG-23037129-01
Batch code: EUDKVE-23037129
Client code: CA0000578
Received on: 04.05.2023

Analytical Report

Sampling Point	Drikkevand fra Færøerne - / 4999110200
Sample type:	Drinking water - Other
Sampling:	
Sampler:	Rekvirenten
Test period:	04.05.2023 - 19.05.2023

Sample description: 1-23-00831-2

Lab sample No.:	835-2023-03712901	Unit	Limit values		LOQ	Method	n) Urel (%)
			Min.	Max.			
Inorganic Compounds							
Nitrites (NO ₂)	< 0.001	mg/l			0.001	DS ISO 15923-1:2013	A 15
Nitrate	< 0.3	mg/l			0.3	DS/ISO 15923-1:2013, mod	A 15
Chloride	18	mg/l			1	DS ISO 15923-1:2013	A 15
Fluoride	< 0.05	mg/l			0.05	DS/ISO/TS 15923-2:2017	A 15
Sulphate	3.1	mg/l			0.5	DS ISO 15923-1:2013	A 15
Cyanide, total	< 1	µg/l			1	DS/EN ISO 14403:2012	A 15

Subcontractors:

A: Eurofins Environment A/S (DS EN ISO/IEC 17025 DANAK 168)

Batch comments:

Since the samples are received after 24 hours from time of sampling the results on analyses which should be conducted within the first day should be interpreted with caution.

19.05.2023

Customer center
 Tel 70224256
 Rentvand@eurofins.dk


 Kirsten Nottelmann
 Client adviser

Legend:

<: less than

>: greater than

#: none of the parameters are detected

LOQ Limit of quantification

*): Not included in the accreditation

n.d: not detected

NM: non-measurable

n): subcontractors

Urel (%): The expanded relative measurement uncertainty, with a coverage factor 2. For results at the level of detection limit the uncertainty might be higher than reported.

°): Uncertainties of microbiological parameters are given as a logarithmical standard deviation

The test results relate only to the items tested.

The report shall not be reproduced except in full without the written approval of the testing laboratory.