



Batch code EUDKVE-23037129

Case Drikkevand fra Færøerne

Case No.

Sampling: Date/init /Rekvirenten

ReceptionsDate 04-05-2023

ReportDate (latest version) 19-05-2023/AR-23-CG-23037129-01

Lab sample No. 835-2023-03712901

Sample description 1-23-00831-2

DGU no

Parameter	Result	Unit	DL	Method				
Nitrites (NO <sub>2</sub> )	< 0,001	mg/l	0,001	DS ISO 15923-1:2013				
Nitrate	< 0,3	mg/l	0,3	DS/ISO 15923-1:2013, mod				
Chloride	18	mg/l	1	DS ISO 15923-1:2013				
Fluoride	< 0,05	mg/l	0,05	DS/ISO/TS 15923-2:2017				
Sulphate	3,1	mg/l	0,5	DS ISO 15923-1:2013				
Cyanide, total	< 1	µg/l	1	DS/EN ISO 14403:2012				