

Heilsufrøðiliga starvsstovan
Smyrilsvegur 7, 2. hædd
FO-100 Tórshavn
Att.: kemi@hfs.fo

Report code: AR-25-CG-25035349-01
Batch code: EUDKVE-25035349
Client code: CA0000578
Received on: 02.05.2025
Authentication code: 142891C9E2

Analytical Report

Sampling Point Drikkevand fra Færøerne - / 4999110200
Sample type: Drinking water
Sampling: 29.04.2025
Sampler: Requester
Test period: 02.05.2025 - 08.05.2025

Sample description: 1-25-01654-1

Lab sample No.:	835-2025-03534901	Unit	Limit values **		LOD	Method	n) Urel (%)	
			Min.	Max.				
<i>Inorganic Compounds</i>								
Chloride	14	mg/l		250	1	DS ISO 15923-1:2013	A	15
Cyanide, total	< 1	µg/l		50	1	DS/EN ISO 14403:2012	A	15
Fluoride	< 0.05	mg/l		1.5	0.05	DS/ISO/TS 15923-2:2017	A	15
Nitrate	< 0.3	mg/l		50	0.3	DS/ISO 15923-1:2013, mod	A	15
Nitrites (NO2)	< 0.001	mg/l		0.1	0.001	DS ISO 15923-1:2013	A	15
Sulphate	1.9	mg/l		250	0.5	DS ISO 15923-1:2013	A	15

Information from client

Accredited sampling No

Subcontractors:

A: Eurofins Environment A/S (DS EN ISO/IEC 17025 DANAK 168)

Interpretation of results according to water quality criteria is only indicative, since sampling is not done accredited.

Report comments:

Eurofins Environment Water A/S waives responsibility for information supplied by the customer. The analysis results apply only to the sample as received.

Batch comments:

Since the samples are received after 24 hours from time of sampling the results on analyses which should be conducted within the first day should be interpreted with caution.

Results meet the limits requirements from Miljøministeriets BEK nr 221 af 25/02/2025 (Drikkevandsbekendtgørelsen).

08.05.2025



In doubt about the authenticity?
Scan the QR code
Or go to
<https://reports.et.dk.eurofins.com>

Customer center
Tel 70224256
rentvand@etn.eurofins.com

Eurofins Miljø Vand A/S
Kundecenter

Legend:

<: less than

>: greater than

#: none of the parameters are detected

LOD: Limit of detection

*): Not included in the accreditation

n.d: not detected

NM: non-measurable

n): subcontractors

Urel (%): The expanded relative measurement uncertainty, with a coverage factor 2. For results at the level of detection limit the uncertainty might be higher than reported.

°): Uncertainties of microbiological parameters are given as a logarithmical standard deviation

**): Miljøministeriets BEK nr 221 af 25/02/2025 (Drikkevandsbekendtgørelsen).

The test results relate only to the items tested.

The report shall not be reproduced except in full without the written approval of the testing laboratory.