

ANALYSUSERTIFIKAT



VESTMANNA KOMMUNA
Sak: Vestmanna Kommuna, vatn

Mál nr.: 1-25-01654
Svarseðil nr.: 021317
Móttøkudagur: 29-04-25
Kanning byrjað: 29-04-25

ANALYSUSERTIFIKAT

VESTMANNA KOMMUNA
Sak: Vestmanna Kommuna, vatn

Mál nr.: 1-25-01654
Svarseðil nr.: 021317
Móttøkudagur: 29-04-25
Kanning byrjað: 29-04-25

Sýni-ID	1-25-01654-001	1-25-01654-002		
Sýnislýsing	Byrgisvegur	í Vestri		
Sýnisslag	Drekkivatn	Drekkivatn		
Tøkudagur	29-04-25	29-04-25		
Analysunavn			Eind	Óvissa Metoda Mark
Litur	12	12	mg Pt/L	13% DS/EN ISO 7887, C, 2012 20
Turbiditetur	0,3	0,6	NTU	30% DS/EN ISO 7027-1, 2016, mod 1
pH	7,0	6,9		3% DS/EN ISO 10523, 2012 mod. 6,5 - 9,5
Leiðingarevni	6,7	6,6	mS/m	8% DS/EN 27888, 2003, mod. 250
Ammonium	<0,015		mgN/L	25% Hach method LCK 304 0,5
Mikroorganismur við 22° C		2 est	CFU/mL	DS/EN ISO 6222/Till.1, 2002 100
* Luktur	Ikki ávíst			I.a.f.
Koliiformar bakteriur, MF		<1	CFU/100mL	DS/EN ISO 9308-1, 2014 0
E.coli, MF		<1	CFU/100mL	DS/EN ISO 9308-1, 2014 0
Mikroorganismur við 22° C	5 est		CFU/mL	DS/EN ISO 6222/Till.1, 2002 100
Enterokokkar, kunnandi		<1	CFU/100mL	DS/EN ISO 7899-2:2000 <>0
Koliiformar bakteriur, MF	<1		CFU/100mL	DS/EN ISO 9308-1, 2014 0
E.coli, MF	<1		CFU/100mL	DS/EN ISO 9308-1, 2014 0
Clostridium perfringens (2)	<1		CFU/100mL	DS/EN ISO 14189:2016 0
Enterokokkar, kunnandi	<1		CFU/100mL	DS/EN ISO 7899-2:2000 <>0
Aluminium, Al	0,017		mg/L	30% DS/EN ISO 17294-2, 2016, mod. 0,2
Antimon, Sb	<0,2		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 5
Arsen, As	<0,1		µg/L	30% DS/EN ISO 17294-2, 2016, mod. 10
Blýggj, Pb	<0,2		µg/L	30% DS/EN ISO 17294-2, 2016, mod. 10
Bor, B	0,005		mg/L	25% DS/EN ISO 17294-2, 2016, mod. 1
Kadmium, Cd	<0,1		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 5
Krom, Cr	<0,2		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 50
Jarn, Fe	0,07		mg/L	25% DS/EN ISO 17294-2, 2016, mod. 0,2
Kopar, Cu	32,6		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 100
Kyksilvur, Hg	<0,05		µg/L	30% DS/EN ISO 17294-2, 2016, mod. 0,5
Mangan, Mn	<0,007		mg/L	25% DS/EN ISO 17294-2, 2016, mod. 0,05
Natrium, Na	6,926		mg/L	30% DS/EN ISO 17294-2, 2016, mod. 200
Nikkul, Ni	<0,4		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 20
Selen, Se	<0,4		µg/L	25% DS/EN ISO 17294-2, 2016, mod. 10
* Kanningar sendar Eurofins í DK	sí hjálagt			

ANALYSUSERTIFIKAT

VESTMANNA KOMMUNA
Sak: Vestmanna Kommuna, vatn

Mál nr.: 1-25-01654
Svarseðil nr.: 021317
Móttøkudagur: 29-04-25
Kanning byrjað: 29-04-25

Sýni-ID	1-25-01654-001	1-25-01654-002	
Sýnislýsing	Byrgisvegur	í Vestri	
Sýnisslag	Drekkivatn	Drekkivatn	
Tøkudagur	29-04-25	29-04-25	
Analysunavn	Eind		Óvissa Metoda Mark
* Nitritt(1)	<0,001	mg/L	<>0,05
* Nitrat(1)	<0,3	mg/L	<>10
* Klorid(1)	14	mg/L	<>200
* Fluorid(1)	<0,05	mg/L	<>1,5
* Sulfat(1)	1,9	mg/L	<>100
* Cyanid(1)	<1	µg/L	<>10

(1) Undirveitari: Eurofins Miljø, DANAK test reg. nr. 168

Viðmerkingar

1-25-01654 Sí viðløgdu analysurapport, batch code EUDKVE-25035349, frá Eurofins Miljø Vand.

Viðmerkingar

Markvirði/Limit values: frá "Kunngerð nr. 127, um veiting av drekkivatni, 22. nov. 2013 & 103, 9. juli 2019"

Vár Róin, Yvirlaborantur, 19-05-25

Móttakaralisti: VESTMANNA KOMMUNA, Bókhald vfv, Jákup Durhuus, Tórbjörn Egholm